

Annexure-C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 182

Dated: 02/04/2024

It is certified that an inspection team headed by Dr. Himanshu Yadav-Executive Engineer

(Name of Officers with designation) from Jal Nigam ,Prayagraj (PHED/Municipality)

Inspected the Access International School-Malak Balau-Nawabganj-Prayagraj-Uttar

Pradesh(Name & Address of the school) on 02/04/2024 (date of inspection) and on the basis

of Water Test Report (Attached) bearing no 557 dated 27/03/2024 of PRAYAGRAJ JAL KAL

VIBHAG LABORATORY (PHED Lab)certified that the Access International School-Malak

Balau-Nawabganj-Prayagraj-Uttar Pradesh (Name of school) has safe drinking water facilities

for the students and members of staff of the institution. School is also maintains the hygienic

sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid from to 02/04/2024 to 01/01/2027(03 Years).

Executive Engineer
Jal Nigam
Prayagraj


02/04/24

Signature with Seal: 

Name : **Dr. Himanshu Yadav**

Designation : **Executive Engineer**

Name & Address of the Office/Department:

Jal Nigam Prayagraj

To

The Manager

Access International School

-Malak Balau-Nawabganj-

Prayagraj-Uttar Pradesh

(Name & Address of the Institution)



PRAYAGRAJ JAL KAL VIBHAG LABORATORY
CHEMICAL ANALYSIS OF WATER
Test Report

कार्यालय महाप्रबन्धक
जलकल विभाग-नगर निगम
प्रयागराज

S NO - 557

1. Source of sample - Water sample, **Access International School,**
Malak Balau, Nawabganj, Prayagraj.

पत्र संख्या 557 म.प्र.ज. 2024

2. Date of Sampling- 17/03/2024 Received

दिनांक...21/03/2024

3. Date of Analysis- 17/03/2024

Physico Chemical Parameter	BIS Limits IS 10500 : 2012		Result of test
	Requirement (Desirable Limit) Mg/l	Permissible limit In the absence of Alternate source Mg/l	
4. Total Dissolved solids	500	2000	351
5. Hardness Total as CaCO ₃	200	600	188
6. Hardness Temporary as CaCO ₃	NS	NS	94
7. Hardness Permanent as CaCO ₃	NS	NS	94
8. Chlorine as Chlorides Cl	250	1000	100
9. Total Alkalinity as CaCO ₃	200	600	50
10. Nitrites as NO ₂	NS	NS	NIL
11. Iron as Fe	0.3	No relaxation	NIL
12. Fluoride as F	1.0	1.5	0.8
13. Colour Hazen Unit	5	1.5	Colourless
14. Taste	Agreeable	Agreeable	Net tested
15. Odour	Agreeable	Agreeable	Odourless
16. pH Value	6.5 to 8.5	No relaxation	7.2
17. Conductivity as μ mosh at 20°C	NS	NS	501
18. Turbidity NTU	1	5	1
19. Free Residual Chlorine	0.2	NS	Nil

Remarks

Potable


Chemist



Ex. Engg. (HQ)

अधिसारी अभियन्ता (मुख्यालय)
जलकल विभाग-नगर निगम

Copy forwarded for information to

1. The addl. Director, State Health Institute, Sector-C. Chetan Bihar, Aliganj, Lucknow UP.
2. Chief Medical Officer, Prayagraj.
3. Mukhya Nagar Swasthya Adhikari, Nagar Nigam. Prayagraj.
4. Nagar Ayukta, Nigar Nigam, Prayagraj.
5. The Superintending Engineer (R&D) office of Addl. Chief Engineer (PPR&D), U.P. Jal Nigam, 6 Rana Pratap marg, Lucknow.
6. Chairman, jalkal Vibhag/Mayor, Nigam, Prayagraj.
EX. Engg. (HQ)


CC (HQ)


PRAYAGRAJ JAL KAL VIBHAG LABORATORY

Result of the Bacteriological examination of the Water taken from Water Sample

Name & Designation of the person collecting the sample MR. ANJANI KUMAR (PRINCIPAL)

S.No	Date & time of collection	Date of receipt and inoculation	Source of Sample	Colony Count on agar plate in 1 ml		Presumptive coliform count			Probable No. of coliform organism in 100 ml. of original water	Free residual chlorine mg/l	Remarks	
				At 37° C in 48 hours	At room temperature in 72 hours	Quantity of water put up in each tube/No. of tubes put up	50 ml.	10 ml.				1 ml.
							No. of tube showing positive reaction					
1.	17/03/2024	17/03/2024	Water Sample Access International School, Malak Balau, Nawabganj, Prayagraj	—	—		1	5	5	0	NIL	Excellent




 अधिशासी अभियन्ता (मुख्यालय)
 Ex. Engineer (H.Q.)
 जलकल विभाग, प्रयागराज